

---

# **RECYCLING ENERGY: USING STEAM TURBINES TO CONVERT BOILER WASTE INTO ELECTRIC POWER**

**Presentation for  
2005 New England Kiln Drying Association  
Danbury, Connecticut  
October 20, 2005**

Dan Kempland  
Business Development  
161 Industrial Blvd.  
Turners Falls, MA 01376  
[www.turbosteam.com](http://www.turbosteam.com)







## Too many lumber drying mills “leave \$20 bills on the ground”.

- Economic theory says \$20 bills are never on the ground – experience says otherwise
- Conventional dry kiln/sawmill design leaves \$ on the table by failing to convert energy waste into high-value electricity.
  - Potential to generate zero-marginal cost electricity in most lumber mills.
  - Reduce mill operating costs / boost mill profitability
  - Can be used to enhance reliability of mill electric supply
  - Can be used to enhance power factor of mill electricity (avoid \$/kVAR charges, get more useful kWh/kWh purchase)
  - Can create cost-effective means of mill waste disposal
  - Reduces environmental impact of mill operations (eligible for \$-support from CO<sub>2</sub> offsets in some cases).




## Understanding 75% of US power generation in 30 seconds or less...





## Understanding lumber mill energy plants in 30 seconds or less...

Lumber Mill Energy Plant



## The opportunity





---


## Several non-intuitive benefits of this approach.

- The presence of the lumber kiln makes this generation ~ 3X as efficient as the central power it displaces.
  - Average Rankine plant converts only 33% of fuel into useful energy – 2/3rds goes to cooling tower.
  - Use of heat in dry kiln eliminates this efficiency penalty
  - Ensures that marginal generation cost is always less than utility kWh.
- Since 75% of the power plant is already built, the capital costs per kW installed are much less than central stations, despite the relative diseconomies of scale.
  - 1,000 MW Rankine plant typical capital costs ~ \$1 billion (\$1,000/kW)
  - 1 MW steam turbine generator integrated into existing lumber mill typical capital costs ~ \$500,000 (\$500/kW)
- Similar logic applies to non-fuel operating costs
  - Rankine power plant typical O&M costs ~ 1 c/kWh
  - Long term Turbosteam service contract on 1 MW unit ~ 0.1 c/kWh


## Other design possibilities

- If waste wood supply is able to produce more steam than is needed in kilns, can make economic sense to reduce pressure of some or all steam further in a condensing turbine-generator to make more lbs/kW

### Condensing (C) Configuration




### Backpressure/Condensing (BP+C) Configuration



- Value can be enhanced by boosting boiler pressure and/or reducing kiln pressure to increase kW production per lb of steam. (Often possible without modifying existing equipment simply by easing back on operating pressure margins built into existing designs)
- Generator can be designed to provide ancillary benefits in addition to kWh savings (e.g., enhance reliability, power factor)




We have installed 109 systems in the U.S., and 176 worldwide.





**18 of these installations are in the lumber and wood products industries.**





**Cox Interior, Inc. is a Campellsville, KY manufacturer of poplar, oak and cherry interior wood products.**

- Founded in 1983
- Manufactures variety of wood products (stairs, doors, mantels, etc.) in 500,000 sq. ft. facility in Campbellsville, KY
- 750 Employees
- Wood-wastes combusted in boilers to raise steam for process thermal loads





## Description of CHP project

- 4 MW condensing turbine installed in 1990. Boiler operates on wood waste generated in plant to produce ~11.3 million kWh/year.
- 1 MW backpressure system installed in 2002 reduces 45,000 lbs/hr of steam from 235 psig/490°F at boiler down to 30 psig to dry lumber (peak capacity = 1.4 million board-feet). Pressure to kilns is reduced to 15 psig in summer to boost turbine-generator power output per lb of steam.
- Economics (backpressure only)
  - Total installed cost = \$500,000
  - Electricity generation in 2004 = 2,077,414 kWh
  - Energy savings in 2004 = \$120,490
  - 23% 15-year return on assets (projected)
- In total: On-site generation produces 61% of on-site power needs, saves \$775,000 in expenses per year.
- Environmental Bonus: Displacement of dirtier generation from the grid reduces CO<sub>2</sub> emissions by 15,000 tons/year




[www.coxinterior.com](http://www.coxinterior.com)



## A final observation on system design: the key to a successful project is to customize equipment for specific site objectives.

### Example: Midwest Steel Mill (Now in design stage)

PRV reduces 900 psig steam down to 150 psig for plant-wide distribution




#### Design for Peak flow?

- 11.9 MW rated power
- 43.3 million kWh/yr
- \$1.4 million annual savings
- 3 year simple payback

#### Design for baseload?

- 2.4 MW rated power
- 21.0 million kWh/yr
- \$672 K annual savings
- 2.7 year simple payback



---


**Our approach is to identify and design to customer-specific financial objectives.**

**1. Identify Design with Most Rapid Capital Recovery**

- Below this flow, incremental gains in turndown efficiency are offset by sacrificed peak power and higher \$/kW costs
- 180,000 lbs/hr design flow
- 6.5 MW rated power output
- \$1.44 million/year annual savings
- 2.2 year simple payback (46% ROA)

**2. Identify Design with Highest Annual Energy Cost Savings**

- Above this flow, incremental gains in peak power production are offset by sacrificed low-end efficiency
- 275,000 lbs/hr design flow
- 10 MW rated power output
- \$1.59 million/year annual savings
- 2.5 year simple payback (40% ROA)



**The final design selected is customized for to balance technical, financial and operational constraints.**

<b>Final Design</b>	<ul style="list-style-type: none"><li>• 7.8 MW</li><li>• 216,000 lbs/hr design flow</li><li>• 900 psig / 825 inlet → 150 psig exhaust</li></ul>
<b>Financial Performance</b>	<ul style="list-style-type: none"><li>• 45.6 million kWh/year generation</li><li>• \$1.5 million/year annual energy savings</li><li>• 45% gross ROA</li><li>• 21% marginal ROA</li></ul>
<b>Key points</b>	<ul style="list-style-type: none"><li>• Good CHP plants are <u>necessarily</u> custom-designed</li><li>• Optimum design must factor in variable thermal loads, energy rates, financial objectives, turndown curves and subcomponent-vendors product limitations / “sweet spots”</li><li>• Designing strictly for a payback or cash generation runs the risk of leaving money on the table OR making poor use of final capital dollars.</li><li>• Similar logic applies to “power-first” CHP plants.</li><li>• <b>Find a partner who has the ability to help you work through these design constraints.</b></li></ul>



## So is there an opportunity in your facility?

	Typical Values	Extreme Values
Target Financial Return	<2 years simple payback from energy savings	Above-market returns and/or Non-financial drivers
Inlet Steam Pressure	>150 psig	15 psig
Pressure drop across turbine-generator	>100 psig	15 psig
Steam flow	>10,000 lbs/hr	2,500 lbs/hr
Annual steam load factor	>6 months/year	3 months/year
Local electricity rate	>4 c/kWh	>1.7 c/kWh